



**KEY:**

- BOUNDARY OF LICENSED PREMISES
- - - ESCAPE ROUTES
- AREA OF ACCESS TO MEMBERS OF THE PUBLIC
- 30 MINUTE RATING
- ⊗ AREA COVERED BY EMERGENCY LIGHTING (TO BE SHOWN)
- I ILLUMINATED ARROW INDICATES DIRECTION TO EXIT
- 🔔 FIRE ALARM BELL
- ⊙ S SMOKE DETECTOR
- ⊙ H HEAT DETECTOR
- ⊙ B BEACON
- ⊙ CP CALL POINT (BREAK GLASS UNIT)
- FAP FIRE ALARM PANEL
- REF REPEATER PANEL
- W WATER EXTINGUISHER
- C CO2 EXTINGUISHER
- F FOAM EXTINGUISHER
- EB FIRE BLANKET
- ANSUL ANSUL FIRE SUPPRESSION SYSTEM
- AAS ANSUL ACTIVATION SWITCH
- FD60 60 MIN FIRE DOOR - SELF CLOSING & INTUMESCENT SMOKE SEALS
- FD30 30 MIN FIRE DOOR - SELF CLOSING & INTUMESCENT SMOKE SEALS
- S13 FIRE DOOR KEEP SHUT
- S14 FIRE DOOR KEEP LOCKED
- S22 FIRE EXIT OR EMERGENCY EXIT NOTICE OR EQUIVALENT GRAPHIC SYMBOL

**Category of alarm system.**  
 Gent Nano automatic addressable fire detection system category L2 to BS5839: Part 1:2002. Installed to cover all areas in the restaurant demise. Include for link to provide interface with landlords alarm in other areas as required.

**INFORMATION**

**mackenzie wheeler**

ARCHITECTS & DESIGNERS  
 Embankment Studios The Embankment Putney  
 London SW15 1LB  
 T +44 (0)20 8785 5000 F +44 (0)20 8785 5001

Client  
**WAGAMAMA**  
 Project  
**WAGAMAMA**  
 02 CENTRE  
 FINCHLEY ROAD, LONDON

Drawing  
**PROPOSED LICENSING DRAWING**

Drawing No.	Rev
1170/500	/

Scale	Size	Drawn	Date
1:100	A3	RS	July 2012.

ALL DIMENSIONS, SETTING OUT AND LEVELS MUST BE CHECKED ON SITE AND NOT SCALED OFF THIS DRAWING BEFORE ORDERING AND STARTING WORK ON SITE.  
 © MACKENZIE WHEELER LTD